

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

RECEIVED

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
SALEM, OREGON

State Well No. 23/34-7R

State Permit No.

(1) OWNER:

Name Jack Arnold
Address Lane, Oreg.

(2) LOCATION OF WELL:

County Harney Driller's well number
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 76'4" ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used

Size of perforations 3/4 in. by 6 in.
perforations from 19 ft. to 76'4" ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal concrete
Depth of seal 18 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3" & 3/4"
Gravel placed from 18 ft. to 76' ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 7 ft. below land surface Date 5-2-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom?

Yield: 380 gal./min. with 50 ft. drawdown after 8 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 77 ft. Depth of completed well 76' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Well sealed to 24"	0	27
From 6"		
TOP SOIL	0	15
MIXED CLAY & GRAVEL	15	20
YELLOW CLAY	20	30
CLAY & GRAVEL MIX	30	70
FINE SAND & CLAY	70	75

Work started 4-20-1963 Completed 5-2-1963
Date well drilling machine moved off of well 5-3-1963

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Rosberg (Type or print)

Address Box 443

Drilling Machine Operator's License No. 269

[Signed] John Rosberg (Water Well Contractor)

Contractor's License No. 212 Date 7-29-1966

(USE ADDITIONAL SHEETS IF NECESSARY)