

RECEIVED

NOTICE TO WATER WELL CONTRACTOR 1966

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER

STATE OF OREGON

(Please type or print)

8311 Ham

State Well No.

24/30-17D

State Permit No.

(1) OWNER:

Name Adolph Kissle
Address Hines, Oreg. Well #3

(2) LOCATION OF WELL:

County Harney Driller's well number
Bearing and distance from section or subdivision corner
NW 1/4 NW 1/4 NW 1/4
150 ft south
10 ft east
N.W. corner sec 17-24-30

(3) TYPE OF WORK (check):

Well [checked] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [checked] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [checked] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 60 ft. Gage 250

(7) PERFORATIONS:

Perforated? [] Yes [checked] No
Type of perforator used
Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [checked] No
Manufacturer's Name
Model No.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 2.0 ft. Was a packer used? no
Diameter of well bore to bottom of seal 1.0 in.
Were any loose strata cemented off? [] Yes [checked] No
Was a drive shoe used? [checked] Yes [] No
Was well gravel packed? [] Yes [checked] No
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [checked] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 5/1/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [checked] Yes [] No
Yield: 1200 gal./min. with 60 ft. drawdown after 3 hrs.

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 220 ft. Depth of completed well 220 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include TOP SOIL + HARD PAN, PEE GRAVEL, CEMENT GRAVEL, CLAY + GRAVEL MIX, SANDSTONE, DUMMIE ROCK, SANDSTONE, BLACK LAVA ROCK.

Work started 4/21 1966 Completed 4/30 1966
Date well drilling machine moved off of well 5/1/66

(13) PUMP:

Manufacturer's Name Western
Type Turbine H.P. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John W. Rossberg
Address Box 443 Burns, Oreg.
Drilling Machine Operator's License No. 269
Contractor's License No. 272 Date 5/1/66