NC

RECEIVED
MAY 23 1965
STATE ENGINEER
SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

992 Hamon

State Well No. 24/33-9A
State Permit No.

(1) OWNER:
Name [illegible] Dewey [illegible]
Address Crane, Oreg. Dewey KIEM

(2) LOCATION OF WELL:
County Harney Driller's well number
NE ¼ NE ¼ Section 9 T. 24 R. 33 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
12" Diam. from 0 ft. to 237½ ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to 227½ ft. Gage

(7) PERFORATIONS: Perforated? ☑ Yes ☐ No
Type of perforator used Torch
Size of perforations 3/16" in. by 6" in.
perforations from 18' ft. to 98' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Concrete
Depth of seal 18' ft. Was a packer used? yes
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/8" to 3/4"
Gravel placed from 18 ft. to ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 3 ft. below land surface Date 4/24/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? driller
Yield: 600 gal./min. with 55 ft. drawdown after 6 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Cool Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 342 ft. Depth of completed well 262 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil	0	4
Clay	4	18
Clay & sand mix	18	30
Blue Clay	30	60
Black Clay & sand streaks	60	80
Clay (Black)	80	140
Green Clay	140	275
Yellow Clay	275	340
Medium Black sand	340	342

Work started 12/20 1964 Completed 4/24 1965
Date well drilling machine moved off of well 19

(13) PUMP:
Manufacturer's Name ?
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME John W. Rossberg (Person, firm or corporation) (Type or print)
Address Box 443 Burns, Oreg
Drilling Machine Operator's License No. 269
[Signed] John W. Rossberg (Water Well Contractor)
Contractor's License No. 272 Date 4/28, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)