

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
(Please type or print)

DEC 4 1973

State Well No.

365/4W-12

STATE ENGINEER  
SALEM, OREGON

State Permit No.

(Do not write above this line)

(1) OWNER:

Name Joe Corallo  
Address 1246 2nd Ave. Gold Hill, Ore. 97526

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

6" Diam. from 0 ft. to 52 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No

Type of perforator used \_\_\_\_\_

Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? DRILLER

Yield: 20 gal./min. with 31 ft. drawdown after 1 hrs.  
" " " " "  
" " " " "

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Artesian flow \_\_\_\_\_ g.p.m.

Temperature of water 51° Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT  
Well sealed from land surface to 40 ft.  
Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 3 1/2 sacks

Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks

Brand name of bentonite \_\_\_\_\_

Number of pounds of bentonite per 100 gallons \_\_\_\_\_ lbs./100 gals.

of water \_\_\_\_\_

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.

Did any strata contain unusable water?  Yes  No

Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_

Method of sealing strata off \_\_\_\_\_

Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_

Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number \_\_\_\_\_  
1/4 Section 12 T. 36-5 R. 4W W.M. \_\_\_\_\_  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.

Depth at which water was first found 62 ft.  
Static level 25' ft. below land surface. Date 10/17/73  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 80 ft. Depth of completed well 80 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CLAY, SAND, GRAVEL, MCO	0	34	
FRACTURED BASALT BEDROCK	34	80	25'
AQUIFER	62	72	20 gpm

Work started 10/17 1973 Completed 10/17 1973

Date well drilling machine moved off of well 10/17 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] D. Overstreet Date 10/2, 1973  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 810

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name P. AQUIN Drilling Co.  
(Person, firm or corporation) (Type or print)

Address 1840 Willow Ln. Grants Pass, Ore

[Signed] C.F. Overstreet  
(Water Well Contractor)

Contractor's License No. 546 Date 11/29, 1973