NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

SAC 1075 69

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED NOV 28 1972 STATE ENGINEER SALEM, OREGON

State Well No. 36S/4W-14

State Permit No.

(1) OWNER:
Name DUANE BENHAM
Address 1863 Ward's Cr. Rd. Rogue River, Oreg.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 111 ft. Gage 0.25
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 60 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 54° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 3 sacks
Number of sacks of bentonite used in well seal — sacks
Brand name of bentonite —
Number of pounds of bentonite per 100 gallons of water — lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs — Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Jackson Driller's well number
¼ ¼ Section 14 T. 36 R. 4W. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 90 ft.
Static level 40 ft. below land surface. Date 11-17-72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 136 ft. Depth of completed well 136 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil	0	1'	
Red clay	1'	20'	
Streaks Red & yellow clay	20'	90'	85'
Hard grey clay & boulders	90'	132'	
Fractured hard yellow claystone - WB	132'	136'	40

Work started 11-2 1972 Completed 11-17 1972
Date well drilling machine moved off of well 11- 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Claude H. Witcher (Drilling Machine Operator) Date 11-18, 1972
Drilling Machine Operator's License No. 371

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name C. H. WITCHER (Person, firm or corporation) (Type or print)
Address 4280 Foothill Blvd. Grants Pass.
[Signed] Claude H. Witcher (Water Well Contractor)
Contractor's License No. 453 Date 11-18, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119