

WATER WELL REPORT
STATE OF OREGON

JACK
10801

RECEIVED

AUG 27 1981 State Well No. 365/4W-15cd

WATER RESOURCES DEPT
SALEM, OREGON State Permit No.

(1) OWNER:

Name City of Rogue River
Address 133 BROADWAY
City ROGUE RIVER State OR. 97537

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Rotary Mud Dug Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Threaded Plastic Welded
8" Diam. from 0 ft. to 9.4 ft. Gauge 2.50

(6) LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Air test 120 gal./min. with drill stem at 177 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 12 sacks
How was cement grout placed? GROUT PUMP

Was pump installed? no Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number 152
SE 1/4 SW 1/4 Section 15 T. 36S R. 4W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: BROOKSIDE

(11) WATER LEVEL: Completed well.

Depth at which water was first found 80 ft.
Static level 50 ft. below land surface. Date 8/19/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 235 ft. Depth of completed well 235 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	10	
Brown Clay & GRAVEL	10	23	
Brown Clay	23	60	
FRACTURED ROCK	60	94	50
GRAY ROCK W/B	94	200	
GRAY ROCK HARD	200	235	

Work started 8/17 19 81 Completed 8/20 19 81
Date well drilling machine moved off of well 8/20 19 81

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles B. Pelkey Date 8/24, 19 81
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1479

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name McCLANAHAN WELL DRILLING
(Person, firm or corporation) (Type of print)
Address 141 N.E. BEACON DA. GRANTS PASS, OR. 97526
[Signed] Ken McLanahan
(Water Well Contractor)

Contractor's License No. 727 Date 8/24, 19 81