

RECEIVED

JUL 27 1966

WATER WELL REPORT

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, 97310 within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON SALEM, OREGON (Please type or print)

State Well No. 36/4w-16 J
State Permit No.

10980 JACK

(1) OWNER:

Name City of Rogue River
Address Rogue River, Ore.

(2) LOCATION OF WELL:

County Jackson Driller's well number # 2
NE 1/4 SE 1/4 Section 16 T. 36 S. R. 4 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [x] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 152 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [x] Yes [] No
Type of perforator used Mills knife
Size of perforations 4 in. by 1/4 in.
160 perforations from 75 ft. to 95 ft.
40 perforations from 144 ft. to 149 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement and sand
Depth of seal 20 ft. Was a packer used? [x]
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [] Yes [x] No Depth
Was a drive shoe used? [x] Yes [] No
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 18 ft. below land surface Date 5/13/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom?
Yield: 90 gal./min. with 22 ft. drawdown after 24 hrs.
" " " "
" " " "
Bailer test 75 gal./min. with 15 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 201 ft. Depth of completed well 201 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include fine sand (0-6), blue clay coarse gravel (6-95), decomposed green rock (95-149), green rock (149-201).

Work started 5/2 19 66 Completed 5/13 19 66
Date well drilling machine moved off of well 5/13 19 66

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Coleman's Well Drilling
Address 2060 Vine Street
Drilling Machine Operator's License No. 260
[Signed] Joseph E. Coleman
Contractor's License No. 380 Date 7/26, 1966