

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

Jack
11856

State Well No. 37/W-23P

G 2981

State Permit No. _____

(1) OWNER:

Name A. N. Napolitano
Address 3099 E. McAndrews
Medford Oregon

(2) LOCATION OF WELL:

County Jackson Driller's well number 8
1/4 Section 23 T. 375 R. 1 W.M.
Bearing and distance from section or subdivision corner 30'
NORTH - 75' WEST OF SE
CORNER OF S4B.

TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6 1/2" Diam. from 0 ft. to 31 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Main. Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Aquagel
Depth of seal 25 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 2-27-63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Baller test 30 gal./min. with AIR ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6 1/4
Depth drilled 180 ft. Depth of completed well 180 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Black clay sticky	0	2
Brown sandstone	2	24
Blue sandstone med.	24	86
Blue shale	86	130
Blue sandstone med.	130	180
Water bearing	140	146
"	170	175
Work started	<u>2-26</u> 19 <u>63</u>	Completed <u>2-27</u> 19 <u>63</u>
Date well drilling machine moved off of well	<u>2-27</u> 19 <u>63</u>	

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MAJORS DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 11516 DENNIS RD C.P.
Drilling Machine Operator's License No. 89
[Signed] Frederick J. Robertson
(Water Well Contractor)
Contractor's License No. 384 Date 2-28, 1963