**WATER WELL REPORT**
**STATE OF OREGON**

Jack 11904

RECEIVED
NOV 19 1981
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 37S/1W-25 CC
State Permit No.

**(1) OWNER:**
Name Hugh GARDNER
Address 2951 Doctors Pk. Rd.
City MEDFORD State OR 97501

**(2) TYPE OF WORK (check):**
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

**(4) PROPOSED USE (check):**
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

**(5) CASING INSTALLED:** Steel ☒ Threaded ☐ Plastic ☐ Welded ☒
6" Diam. from 0 ft. to 75 ft. Gauge 250
" Diam. from ft. to ft. Gauge

**LINER INSTALLED:**
" Diam. from ft. to ft. Gauge

**(6) PERFORATIONS:** Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

**(7) SCREENS:** Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test 20 gal./min. with drill stem at 196 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 51° Depth artesian flow encountered ft.

**(9) CONSTRUCTION:** Special standards: Yes ☐ No ☒
Well seal—Material used Cement Grout
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
How was cement grout placed? Grout Pump
Was pump installed? no Type HP Depth ft.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**
County JACKSON Driller's well number
SW ¼ SW ¼ Section 25 T. 37S R. 1W W.M.
Tax Lot # 307 Lot Blk Subdivision
Address at well location:

**(11) WATER LEVEL: Completed well.**
Depth at which water was first found 80 ft.
Static level 75 ft. below land surface. Date 10/27/81
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:** Diameter of well below casing 6"
Depth drilled 280 ft. Depth of completed well 280 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| ADOBE CLAY | 0 | 15 | |
| BROWN CLAY | 15 | 40 | |
| GRAY SANDSTONE, CLAY SEAMS | 40 | 70 | |
| GRAY SANDSTONE, HARD | 70 | 80 | 75 |
| GRAY SANDSTONE W/ FRACT | 80 | 280 | |

Work started 10/27 1981 Completed 10/27 1981
Date well drilling machine moved off of well 10/27 1981

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Anderson (Drilling Machine Operator) Date 11/17, 1981
Drilling Machine Operator's License No. 809

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name McCLANAHAN WELL DRILLING (Person, firm or corporation) (Type or print)
Address 141 N.E. BEACON DR. GRANTS PASS, OR 97526
[Signed] Ken McClanahan (Water Well Contractor)
Contractor's License No. 727 Date 11/17, 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690