NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.



## WATER WELL REPORT

## STATE OF OREGON

(Please type or print)

(Do not write above this line)



State Well No. 37s/1w 25

(1) OWNER:	(10) LOCATION OF WELL:	
Name ROBERT JACOBSON	County JACKSON Driller's well number	
Address 2123 CAPITAL	W.E. 14 Section 25 T. 375	R. /W. W.M.
MEDFORD, ORE.	Bearing and distance from section or subdivisi	, , , , , , , , , , , , , , , , , , , ,
(2) TYPE OF WORK (check):	APPRO. 200'5. AND 800'W.	
New Well 🕱 Deepening 🗌 Reconditioning 🗍 Abandon 🗍		Contract to the Contract
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Don'th at which water was first to 192	
Rotary Driven Domestic Mindustrial Municipal Domestic	100	
State D. Betted		surface. Date 2-10-77
Dug   Bored     Irrigation   Test Well   Other	Artesian pressure lbs. per squar	re inch. Date
(5) CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well 1	611
6 "Diam from 0 tt to 164 ft Gage . 250	Diameter of wen	
		leted well 405 ft.
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each stratu	and structure of materials;
DED TO BANKONG	with at least one entry for each change of forma	tion. Report each change in
PERFORATIONS: Perforated?  Yes You	position of Static Water Level and indicate prin	cipal water-bearing strata.
Type of perforator used	MATERIAL	From To SWL
Size of perforations in. by in.	Soil BLACK	0 4
perforations from ft. to ft.	CLAY Yellow	4 16
perforations from ft. to ft.	CLAY BROWN	16 24
perforations from ft. to ft.	CLAYSTONE, RED	24 135
(7) SCDEENS.	CLAYSTONE BLUE	1.35 157
(7) SCREENS: Well screen installed?  Yes X No	CLAY STONE, BLUE HARD	157 405 180
Manufacturer's Name		
Type Model No		
Diam. Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is		
lowered below static level	LED 3 41077	
Was a pump test made?   Yes No If yes, by whom?		
d: gal./min. with ft. drawdown after hrs.	WATE: - SOURCES	rept.
" Н Н	SALEM, OREGUN	
Return " "		
Boller-test 60 gal./min. with 325 ft. drawdown after hrs.		
Artesian flow g.p.m.		
rature of water Depth artesian flow encountered ft.	Work started 2-8 1977 Complete	ed 2-10 1977
(A) GONGERNION	Date well drilling machine moved off of well	
(9) CONSTRUCTION:		
Well seal—Material used Portland CEMENT	Drilling Machine Operator's Certification:	
Well sealed from land surface toft.	This well was constructed under my direct supervision.  Materials used and information reported above are true to my	
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge and belief	
Diameter of well bore below seal	[Signed] Lonold Manuso Date 2-10, 1977	
sacks of cement used in well sear	(Drilling Machine Operator) Drilling Machine Operator's License No. 632	
How was cement grout placed? PRESSURE GROUT,	Drilling Machine Operator's License No.	
TRIMMIE PIPE	Water Well Contractor's Certification:	
**************************************	This well was drilled under my jurisdiction and this report is	
Tion of the second of the seco	true to the best of my knowledge and belief.	
Was a drive shoe used? X Yes D No Plugs Size: location ft.	Name MARTINSON WELL DRILLING	
Did any strata contain unusable water? 🗌 Yes 🎢 No	(Person, firm or corporation) (Type or print)	
Type of water? depth of strata	Address 81 BALL Rd. EAGLE POINT, ORE.	
Method of sealing strata off	[Signed] Jrw. marting	a_ )
Was well gravel packed?   Yes No Size of gravel:	[Signed] , Malling (Water Well Contra	actor)
Gravel placed fromft. toft.	Contractor's License No. 406 Date	2 - // 1077