NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 13 1970 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Jack 12042

State Well No. 37/1W-32dd
State Permit No.

(1) OWNER:
Name FRANK S CHAPMAN
Address 5387 McGlonghlin DR C.P. ORE

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☒
12" Diam. from -1 ft. to 39 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
32 perforations from 22 ft. to 38 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 12 ft. below land surface Date 6-26-70
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 42 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:
Well seal—Material used Puddled CLAY
Depth of seal 19' ft.
Diameter of well bore to bottom of seal 18 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Wet depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County JACKSON Driller's well number 1
S/E 1/4 SE 1/4 Section 32 T. 37 R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 12"
Depth drilled 41 ft. Depth of completed well 41 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown CLAY	0	6	
Yellow Brown CLAY	6	28	
Boulders	28	29	
Yellow CLAYSTONE	29	37	
Brown Broken Rock	37	40	
Blue Rock Hard	40	41	

Work started 6-19 1970 Completed 6-26 1970
Date well drilling machine moved off of well 6-26 1970

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] (Drilling Machine Operator) Date 6-28, 1970
Drilling Machine Operator's License No. 75

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Rotary Drilling Co (Person, firm or corporation) (Type or print)
Address 1044 W 12th St
[Signed] (Water Well Contractor)
Contractor's License No. 338 Date 6-28, 1970

(USE ADDITIONAL SHEETS IF NECESSARY)