

RECEIVED  
OCT 7 1959

WATER WELL REPORT  
STATE OF OREGON

Jack  
12051

371W-32B

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. G-980

State Permit No. G-891

(1) OWNER:

Name Horace L. & Wilma Root  
Address 1025 Ellendale Drive  
Medford, Oregon

(2) LOCATION OF WELL:

County Jackson Owner's number, if any—  
NW 1/4 NE 1/4 Section 32 T. 37 S. R. 1 W W.M.  
Bearing and distance from section or subdivision corner  
16.55' S. & 175' E. from NE. Cor  
D.L.C. #50

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 6 ft. Gage 44"

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
SIZE of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 9-19-59  
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] H. L. Root Date 5-26, 1959  
Wilma Root (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? -  
Yield: gal./min. with ft. drawdown after hrs.  
Bailer test 15 gal./min. with 70 ft. drawdown after 1/4 hrs.  
Artesian flow g.p.m. Date  
Temperature of water 54° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 6 inches.  
Depth drilled 94 1/2 ft. Depth of completed well 94 1/2 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Br top soil	0	1'
" sandstone	1	5'
grey granite	5	94 1/2'

Work started 9-12-59 Completed 9-19-59

(13) PUMP:

Manufacturer's Name Parkley  
Type Jet H.P. 1

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME SHULTS Bros Well Drilling  
Address 2034 W. Main St. Medford  
Driller's well number 8  
[Signed] J. H. Shultz (Well Driller)  
License No. 105 Date 5-26, 1959