NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT MAY 1 2 1975 s

	State	Well	No.	5/5	1-20	*** ta
3	2000			7		

(Please type or print) STATE ENGINEER (Do not write above this ISALEM, OREGON State Permit No.

6-7098

(1) OWNER:	(10) LOCATION OF WELL:			
Name Joe Brooks #3	County Jackson Driller's well number			
Address 2704, Steaths Way	SW 1/4 NW4 Section 23 T. 37 R. 2 W.M.			
medford Oregon	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):				
New Well Deepening Reconditioning Abandon Abandon The state of the state				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 7/ ft			
Rotary Driven Domestic Industrial Municipal Domestic	Static level 5 ft. below land surface. Date 4/30/			
Dug	Artesian pressure lbs. per square inch. Date			
CASING INSTALLED: Threaded Welded W	(12) WELL LOG: Diameter of well below casing Depth drilled /02 ft. Depth of completed well /02 ft Formation: Describe color, texture, grain size and structure of materials and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation, Report each change in position of Static Water Level and indicate principal water-bearing strata			
Type of perforator used Torch	MATERIAL From To SWL			
Size of perforations 1/4 in. by 4 in.	clay & gravel 0 70 +5			
33 perforations from 64 ft. to 70 ft.				
perforations fromft. toft.	Brown Rock 70 80 5			
perforations from ft. to ft.				
(7) SCREENS: Well screen installed? ☐ Yes No	Blue Rock 80 102 5			
(1) SCREENS: Well screen installed? Yes PNo Manufacturer's Name				
Type Model No				
Diam Slot size Set from ft. to ft.				
Diam Slot size Set from ft. to ft.				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made? ☐ Yes [YNo If yes, by whom?				
Yield: gal./min. with ft. drawdown after hrs.				
" "				
" " "				
Bailer test 30 gal./min. with 96 ft. drawdown after 2 hrs.				
Artesian flow g.p.m.				
aperature of water Depth artesian flow encountered ft.	Work started 4/29 19 75 Completed 4/30 19 7			
(9) CONSTRUCTION:	Date well drilling machine moved off of well 4/30 19			
Well seal—Material used cement	Drilling Machine Operator's Certification:			
Well sealed from land surface to	This well was constructed under my direct supervision Materials used and information reported above are true to m			
Diameter of well bore to bottom of seal	best knowledge and belief.			
Diameter of well bore below seal in.	[Signed] // (M) // (SCO Date 5/8, 197			
Number of sacks of cement used in well sealsacks	Drilling Machine Operator's License No.			
Number of sacks of bentonite used in well seal sacks	Drining Wachine Operator's Encense No.			
Brand name of bentonite	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is			
of waterlbs./100 gals. Was a drive shoe used? [Yes No Plugs Size: location ft.	true to the best of my knowledge and belief			
Did any strata contain unusable water? Yes No	Name (Person, firm or corporation) (Type or Frint)			
Type of water? depth of strata	Address 2060 Vine St.			
Method of sealing strata off	Ormen P DD			
	[Signed] (Water Well Contractor)			
Was well gravel packed? Yes No Size of gravel:	Contractor's License No. 380 Date 5/8 19.7			