

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

NOV 12 1974

STATE ENGINEER
SALEM, OREGON

State Well No. 375/2w-23bc

State Permit No. 67098

JACK
13303

(1) OWNER:

Name Joe Brooks, #2
Address 2060 N.W. Vine
Medford, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 71 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Torch
Size of perforations 1/4 in. by 4 in.
33 perforations from 63 ft. to 70 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 60 gal./min. with 96 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number
SW 1/4 NW 1/4 Section 23 T. 37S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 64 ft.
Static level 5 ft. below land surface. Date 10-14-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 102 ft. Depth of completed well 102 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---------------|------|-----|-----|
| Clay + Gravel | 0 | 71 | 4 |
| Brown Rock | 71 | 80 | 5 |
| Blue Rock | 80 | 102 | 5 |

Work started 10-10-1974 Completed 10-14-1974
Date well drilling machine moved off of well 10-14-1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Brian A. Paul Date 11-4-1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 850

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Coleman's Well Drilling Company
(Person, firm or corporation) (Type or print)

Address 2060 N.W. Vine, Grants Pass

[Signed] Joseph E. Blum
(Water Well Contractor)

Contractor's License No. 380 Date 11-4-1974