NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JUL 30 1962
STATE ENGINEER
SALEM, OREGON

JACK
1351

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 34/1W-21

State Permit No.

(1) OWNER:
Name FRED NICHOLS
Address P.O. Box 262
SHADY COVE ORE

(2) LOCATION OF WELL:
County JACKSON Driller's well number 1019
¼ ¼ Section 21 T. 34S R. 1 W.M.
Bearing and distance from section or subdivision corner
approx 100 yds west of Antler Lake Rd. 3 mi So of Shady Cove. 4

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☒ Welded ☐
6" Diam. from 0 ft. to 26 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement + Clay.
Depth of seal 26 ft. Was a packer used?
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☒ Yes ☐ No
Type of water? Surface Depth of strata 18 to 20 ft
Method of sealing strata off Cement + Clay.

(10) WATER LEVELS:
Static level 20 ft. below land surface Date July 25 62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 25 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 6 in
Depth drilled 52 ft. Depth of completed well 52 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
gravel + boulders	0	20
gray claystone	21	38
white claystone	38	42
gray claystone	42	52
water at 33-44+51 ft.		

Work started 7/20 1962 Completed 7/25 1962
Date well drilling machine moved off of well 7/25 1962

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME DEISTER'S WELL DRILLING CO. (Person, firm or corporation) (Type or print)
Address P.O. Box 141 Shady Cove Ore.
Drilling Machine Operator's License No. 73
[Signed] Ray Deister (Water Well Contractor)
Contractor's License No. 82 Date 7/26, 1962

(USE ADDITIONAL SHEETS IF NECESSARY)