

K LUE W E D
 JUL 29 1966
STATE ENGINEER
 SALEM, OREGON

JACK
 15299

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the
 STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. **38/1w-23**
 State Permit No.

(1) OWNER: Bridge Dept. STATE OF OREGON Hwy. Comm.
 Name STATE OF OREGON Hwy. Comm.
 Address 2692 NO. PACIFIC HWY Medford, Oregon
(2) LOCATION OF WELL:
 County JACKSON Driller's well number 57
 1/4 Section 2B T. 38S R. 1W W.M.
 Bearing and distance from section or subdivision corner Approx 500' NW of SE corner
Sun Crest Rest Area

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.
(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
 6" Diam. from 0 ft. to 23 ft. Gage 250
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.
 perforations from " ft. to " ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name
 Model No.
 Slot size Set from " ft. to " ft.
 Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal Bentone Cement Grout
 Depth of seal 20 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 9 in.
 Were any loose strata cemented off? Yes No Depth 14
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from " ft. to " ft.
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off

(10) WATER LEVELS:
 Static level 12 ft. below land surface Date 6-28-66
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 43 gal./min. with 11 ft. drawdown after 1 hrs.
 " " " " "
Air " " " " "
 Baller test 60 gal./min. with 80 ft. drawdown after 4 hrs.
 Artesian flow g.p.m. Date
 Temperature of water 56 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6
 Depth drilled 150 ft. Depth of completed well 150 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|---|------|-----|
| Brown Clay-Boulders River Run Small | 0 | 14 |
| Blue shale small layers of white quartzite at water bearing areas | 14 | 150 |
| Water Bearing | 42 | 46 |
| " " | 62 | 66 |
| " " | 102 | 106 |

Work started 6-26 1966 Completed 6-28 1966
 Date well drilling machine moved off of well 6-28 1966

(13) PUMP:
 Manufacturer's Name
 Type: H.P.
Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME Fred Robertson Well Drilling
 (Person, firm or corporation) (Type or print)
 Address 11514 Dennis Rd C.P.
 Drilling Machine Operator's License No. 89
 [Signed] Fred Robertson
 (Water Well Contractor)
 Contractor's License No. 384 Date 6-28 1966