

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

State Well No. 38/2w-15

State Permit No. _____

(1) OWNER:

Name Lambert Johnson
Address Box 15
Jacksonville, Ore

(2) LOCATION OF WELL:

County Jackson Driller's well number 335
1/4 Section 15 T. 38S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐
6" Diam. from 0 ft. to 19 ft. Gage .252
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & sand
Depth of seal 18 1/2 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 47 ft. below land surface Date 9-7-60
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 7 1/2 gal./min. with 50 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 6Depth drilled 112 ft. Depth of completed well 112 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL.	FROM	TO
Gravelly top soil Br.	0	4
Claystone? ft. 11	4	16
11 " Grey Green	16	31
11 " 11	31	49
Media Sedimentary Grey	49	79
11 11 hard 11	79	112
occasional thin white layers from 49' to 112'		

Work started 8-23 1965 Completed 9-2 1965Date well drilling machine moved off of well 9-3 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME M.D. SHULTS Well DrillingAddress 2034 W. MainDrilling Machine Operator's License No. 94[Signed] M.D. ShultsContractor's License No. 105 Date 9-7, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)