NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)



State Well No. 385/2w-29cd
State Permit No.

· · · · · · · · · · · · · · · · · · ·	
(1) OWNER:	(10) LOCATION OF WELL:
Name Dick Boushev	County Jackson Driller's well number 80-67
Address 5054 Sterling Cr. Rd.	SE 14 SW 14 Section 29 T. 38 R. 2W W.M.
Jacksonville Or.	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Tax lot 1100
New Well ☐ Deepening- Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 142 ft.
tary Driven Domestic M Industrial Municipal	Static level 20 ft. below land surface. Date 5/7/80
le Jetted Irrigation Test Well Other	
Glued	Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded □ Welded □	(12) WELL LOG: Diameter of well below casing 6
4" "Diani non -1 ft. to 244 ft. Gage 160	Depth drilled 244 ft. Depth of completed well 244 ft.
"Diam, from ft, to ft, Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
DEDECD AMIONS.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
(F) PERFORATIONS: Perforated? 1 Yes No.	
Type of perforator used Skillsaw	MATERIAL From To SWL
Size of perforations -/ In. by In.	Applegate greenstone some 92 113 20 quartz veins hard
255 perforations from ft. to 18/	
180 periorations from 181 to 211	Basalt grey & green 113 172 20 quartz veins 2 gpm
perforations from ft. to ft.	Basalt grey very hard 172 216 20
(7) SCREENS: Well screen installed? ☐ Yes ৄ No	few quartz veins
Manufacturer's Name	Basalt grey, black & 215 244 20
Type	green all broken w/
Diam. Slot size Set from ft. to ft.	20% quartz veins
Diam Slot size Set from ft. to ft.	All water bearing aquifer in this
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	stata_31.5 gpm for total water 35gpm
as a numb test made? \(\subseteq \text{Yes} \subseteq \text{No If yes, by whom?} \subseteq \text{Triller}	BEOEDVED
vici: 35 gal./min. with 164 ft. drawdown after 1 hrs.	REULIVEU
gar, min. with 104 it. drawdown after 1 ms.	JUN 1 1 1980
	WATER RESOURCES DEPT
iler test gal./min. with ft. drawdown after hrs.	SALEM, OREGON
Artesian flow g.p.m.	5/6 90 5/9 90
Temperature of water 58 Depth artesian flow encountered ft.	Work started 5/6 1980 Completed 5/8 1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well 5/9 19 80
Well seal—Material used no reconstruction on wel	
Well sealed from land surface to Seal necessary ft.	This well was constructed under my direct supervision. Materials used and information reported above are true to my
Diameter of well bore to bottom of seal în.	best knowledge and belief.
Diameter of well bore below seal in,	[Signed] July July Date 6/3 , 1980
Number of sacks of cement used in well seal sacks	(Drilling Machine Operator) Drilling Machine Operator's License No
How was cement grout placed?	Diming Machine Operator's Literise No.
· · · · · · · · · · · · · · · · · · ·	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? Yes No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes I No	Name (Person, firm or corporation) (Type or print)
Type of water? potable depth of strata	AddressP.O. Box 465 Talent Sr. 97540
Method of sealing strata off	Role A buch fall
Was well gravel packed? Yes No Size of gravel:	[Signed] fill (Water Well Contractor)
Gravel placed from the to st	Contractor's License No. 767 Date 6/7 19 00