NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON L V E D

State Well No. 385/2W-29cd

(Please type or print)

(Do not write above this line) 201976

State Permit No. (5-7015

(1) OWNER:	(10) LOCATION OF WELL:		
Name Mac Brown	County Jackson Driller's well number		
Address 5198 Sterling Crk. Rd.		R. 2W W.M.	
Jacksonville, Ore.	Bearing and distance from section or subdivisi	lon corner	
(2) TYPE OF WORK (check):			
New Well □ Deepening □ Reconditioning □ Abandon □			
Indonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	zell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 66 ft.		
Rotary M. Driven Domestic K Industrial Municipal	Static level 20 ft. below land surface. Date 10/13/76		
Cable			
Dug Doted Milgation Test West Other	Artesian pressure lbs. per squar	re inch. Date	
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well I	holow agains 6	
6" Diam. from0. ft. to6.3 ft. Gage25.0	Depth drilled 345 ft. Depth of completed well 345 ft.		
	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,		
DEDECORATIONS.	with at least one entry for each change of forma	tion. Report each change in	
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal water-dearing strata.	
Type of perforator used	MATERIAL	From To SWL	
Size of perforations in. by in.	Soilbrown	0 6	
perforations from ft. to ft.	Claybrown	6 12	
perforations from ft. to ft.	Shattered rockbrown	12 16	
perforations from ft. to ft.	Claygray	16 25	
(7) SCREENS: Well screen installed? Tyes Tyno	Claybrown	25 36	
	Claystonegray	36 52	
Manufacturer's Name	Claystonebrown	52 56	
Type Model No Diam Slot size Set from ft. to ft.	Conglomerategray	56 151	
Slot size Set from ft. to ft.	Granitegray	151 258	
Sec Holl	Basaltblack	258 284	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Basaltgray	<u>284 315 </u>	
Was a pump test made? ☐ Yes ᡯ No If yes, by whom?	Basaltblack	1212 242	
		<u> </u>	
Yield: gal./min. with ft. drawdown after hrs.			
" "			
<u>"AIR</u> " "			
Bailer test 75 gal./min. with 325t. drawdown after 2 hrs.			
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 10/12 19 76Complet	ed 10/13 1976	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	10/13 1976	
Well seal—Material usedCement	Drilling Machine Operator's Certification:	· •	
Well sealed from land surface to	This well was constructed under my direct supervision.		
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge and belief.		
Diameter of well bore below seal	[Signed] Date 10/ 16/17.6		
Number of sacks of cement used in well seal6sacks	(Drilling Machine Operator)	483	
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No.		
Brand name of bentonite			
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is		
Was a drive shoe used? Yes No Plugs Size: location ft.	true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes X No	Name Virgle Gribble Well Drilling (Type of print)		
Type of water? depth of strata	Address 8380 Ramsey Rd., Gold Hill. Ore.		
Method of sealing strata off			
	[Signed] Wayne Mulkow	<i>bec</i>	
Was well gravel packed? ☐ Yes ☒ No Size of gravel:	Water Well Contract 461	10/16 76	
Gravel placed from ft. to ft.	Contractor's License No Date	, 19	