NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORTE CEIVED
State Well No. 388/3W-11
(Go not write above this WATER RESOURCES DEPT.

(1) OWNER:	(10) LOCATION OF WELL:
Namen/ Aileen Bergersen	County Jackson Driller's well number
Addres 2815 Siskiyou Blvd.	14 14 Section 11 T. 38 R. 3W W.M
Ashland, Ore.	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 55 f
Rotary X Driven Domestic I Industrial Municipal	Static level 28 ft. below land surface. Date 11/1/77
Cable	Artesian pressure lbs. per square inch. Date
CASING INSTALLED:  6 "Diam. from 0 ft. to 40 ft. Gage 250  "Diam. from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing 6 Depth drilled 100 ft. Depth of completed well 100 ft Formation: Describe color, texture, grain size and structure of material and show thickness and nature of each stratum and aquifer penetrate with at least one entry for each change of formation. Report each change position of Static Water Level and indicate principal water-bearing strate
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	Soilbrown 0 4
perforations from ft. to ft.	Claybrown 4 10
perforations from ft. to ft.	Claystonebrown 10 32
perforations from ft. to ft.	Claystone-gray 32 48
(7) SCREENS: Well screen installed?   Yes M No	Conglomeratebrown 48 70
Manufacturer's Name	Conglom;erategray 70 80 95
Type Model No.	Basaltgray 95 100
Diam. Slot size Set from ft. to ft.	Basartbrack 95 100
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level	
Was a pump test made?  Yes You If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	
Bailer test 8 gal./min. with $72$ ft. drawdown after $1\frac{1}{2}$ hrs.	
Artesian flow g.p.m.	
nperature of water Depth artesian flow encountered ft.	Work started 11/1 1977 Completed 11/1 197
(9) CONSTRUCTION:	Date well drilling machine moved off of well 11/1 19 7
Well seal—Material used Cement  Well sealed from land surface to 39 ft.  Diameter of well bore to bottom of seal 10 in.  Diameter of well bore below seal 6 in.  Number of sacks of cement used in well seal 7 sacks  How was cement grout placed? poured	Drilling Machine Operator's Certification:  This well was constructed under my direct supervisio Materials used and information reported above are true to mest knowledge and belief.  [Signed]  Drilling Machine Operator's License No. 483
	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report
Was a drive shoe used? ☐ Yes 🏝 No Plugs Size: location ft.	true to the best of my knowledge and belief.  Name Virgle Gribble Well Drilling
Did any strata contain unusable water? 🗌 Yes 🕇 No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address8380 Ramsey Rd., Gold Hill, Ore.
Method of sealing strata off	A Law Marilla
Was well gravel packed?  Yes No Size of gravel:	[Signed] Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 461 Date 11/7 , 19.7