

WATER WELL REPORT

STATE OF OREGON

JACK 17189

RECEIVED

State Well No. 385/3W-27ad

JAN 18 1984

State Permit No.

PLEASE TYPE WATER RESOURCES DEPT.

SALEM, OREGON

(1) OWNER:

Name: Applegate Christian Fellowship
Address: 7380 Highway 238
City: Jacksonville State: OR

(10) LOCATION OF WELL:

County: JACKSON
Driller's well number: 55-83
Section: 27 T. 38 R. 3W
Address at well location: 2380 Highway 238 Jacksonville OR

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven [ ] Domestic [X] Industrial [ ] Municipal [ ]
Rotary Mud [ ] Dug [ ] Irrigation [ ] Test Well [ ] Other [ ]
[ ] Bored [ ] Thermal: Withdrawal [ ] ReInjection [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]
Thermal: Withdrawal [ ] ReInjection [ ]

(11) WATER LEVEL: Completed well.

Depth at which water was first found: 55 ft.
Static level: 8 ft. below land surface. Date: 8-29-83
Artesian pressure: lbs. per square inch. Date:

(12) WELL LOG:

Diameter of well below casing: 6
Depth drilled: 120 ft. Depth of completed well: 20 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Entries include CLAY + GRAVEL (0-10), GRANITE (10-120), and 8.

(5) CASING INSTALLED:

Steel [X] Plastic [ ]
Threaded [ ] Welded [X]
6" Diam. from 1 ft. to 19 ft. Gauge 250

LINER INSTALLED:

4" Diam. from 0 ft. to 120 ft. Gauge

(6) PERFORATIONS:

Perforated? [X] Yes [ ] No
Type of perforator used: SAW
Size of perforations: 1/4 in. by 10 in.
40 perforations from 40 ft. to 120 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name:
Type:
Model No.:
Diam.: Slot Size: Set from: ft. to: ft.
Diam.: Slot Size: Set from: ft. to: ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
d: gal./min. with ft. drawdown after hrs.
Air test: 8 gal./min. with drill stem at 120 ft. 1 hrs.
Bailer test: gal./min. with ft. drawdown after hrs.
Artesian flow: g.p.m.
Temperature of water: 52 Depth artesian flow encountered: ft.

(9) CONSTRUCTION:

Special standards: Yes [ ] No [X]
Well seal—Material used: CEMENT
Well sealed from land surface to: 18 ft.
Diameter of well bore to bottom of seal: 10 in.
Diameter of well bore below seal: 6 in.
Number of sacks of cement used in well seal: 6 sacks
How was cement grout placed? PUMPED DOWN
ANULAR SPACE
Was pump installed? [X] Yes [ ] No Type: HP Depth: ft.
Was a drive shoe used? [X] Yes [ ] No Plugs: Size: location: ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from: ft. to: ft.

Work started: 8-29 19 83 Completed: 8-30 19 83
Date well drilling machine moved off of well: 8-30 19 83

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Pat Cart Date: 1-10, 19 84

Bonded Water Well Constructor Certification:

Bond (number) Issued by: DATA + STAFF Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name: PAT CARTER WELL DRILLING (Person, firm or corporation) (Type or print)
Address: 240 Johnson Rd Jville
[Signed] Pat Cart Water Well Constructor
Date: 1-10, 19 84

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310
within 30 days from the date of well completion. SP\*45292-690