

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

RECEIVED  
JUN 19 1973  
dd  
385/3W-27

**WATER WELL REPORT**  
**STATE OF OREGON**  
(Please type or print) **DATE ENGINEER**  
(Do not write above this line) **EM OREGON**

State Well No. 385/3W-27  
State Permit No. \_\_\_\_\_

**(1) OWNER:**  
Name Seaside Village Water Association  
Address 555 Applegate Rd, Jackson Village, OR

**(2) TYPE OF WORK (check):**  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:** Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):** Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:** Threaded  Welded   
6" Diam. from 0 ft. to 104 ft. Gage 350  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:** Perforated?  Yes  No.  
Type of perforator used Mills  
Size of perforations 3/8 in. by 2 1/2 in.  
104 perforations from 34 ft. to 97 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:** Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " " "  
" " " " " " "  
Flow test 24 gal./min. with 70 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
Well seal—Material used Cement  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal 9 in.  
Diameter of well bore below seal 6 in. 9 \_\_\_\_\_ sacks  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**  
County Jackson Driller's well number \_\_\_\_\_  
SE 1/4 SE 1/4 Section 27 T. 38S.R. 3W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**  
Depth at which water was first found 84 ft.  
Static level 35 ft. below land surface. Date 6-5-73  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:** Diameter of well below casing 6  
Depth drilled 330 ft. Depth of completed well 320 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay & Boulders	0	31	
Brown Clay & Fractures	31	61	
Basalt	61	80	
Brown Clay	80	100	
Fractured Basalt	80	100	
Water Bearing	100	320	
Flow Basalt, quartz seams	100	320	
Small fractures			

Work started 5-31 1973 Completed 6-4 1973  
Date well drilling machine moved off of well 6-4 1973

**Drilling Machine Operator's Certification:**  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Robert Faust Date 6-6, 1973  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 695

**Water Well Contractor's Certification:**  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Geo. W. McCluskey Well Drilling  
(Person, firm or corporation) (Type or print)  
Address 330 N.E. Elida Dr. Grant Pass, OR  
[Signed] Geo. W. McCluskey  
(Water Well Contractor)  
Contractor's License No. 423 Date 6-6, 1973