

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

G6898

Jack
17369

WATER WELL REPORT AUG 22 1973

RECEIVED

STATE OF OREGON STATE ENGINEER
(Please type or print) SALEM, OREGON

State Well No. 385/3W-29bb

(Do not write above this line)

State Permit No. J. C. Permit #79-73W

(1) OWNER:

Name Frank Witthaus
Address 10414 Hwy. 238
Jacksonville, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from +1 ft. to 22 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
pump test 25 gal./min. with 71 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 22 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite National
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Driller's well number
1/4 Section 29 T. 38S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 72 ft.
Static level 15 ft. below land surface. Date 8-7-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 86 ft. Depth of completed well 86 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown clay stone	0	35	
gray basalt	35	72	
broken basalt	72	75	
gray basalt	75	86	

Work started 8-7-73 19 Completed 8-7-73 19
Date well drilling machine moved off of well 8-8-73 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Scott Holt Date 8-8-73, 19...
(Drilling Machine Operator)
Drilling Machine Operator's License No. 750

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Rotary Drilling Co.
(Person, firm or corporation) (Type or print)
Address 1207 Sage Rd. Medford, Ore. 97501
[Signed] U.V. Howlett
(Water Well Contractor)
Contractor's License No. 332 Date 8-8-73, 19...