NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED MAR 20 1979 WATER RESOURCES DEPT. SALEM, OREGON

Jack 17568

State Well No. 38s/4w-5bb

State Permit No.

JOHN ATKINS SLAGLE CK. Rd.

(1) OWNER:

Name John Atkins

Address 755 Slagle Creek Road
Grants Pass, Ore. 97526

(2) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑

8" Diam. from 0 ft. to 90 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☑ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

RECEIVED APR 6 1979 WATER RESOURCES DEPT. SALEM, OREGON

(7) SCREENS: Well screen installed? ☐ Yes ☑ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a ~~pump~~ AIR test made? ☑ Yes ☐ No If yes, by whom? DRILLER

Yield: 30 gal./min. with ft. drawdown after 1 hrs.

" " "

" " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 50° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 12 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal 9 sacks

How was cement grout placed? PUMPED

Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☑ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☑ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number

NW ¼ NW ¼ Section 5 T. 38 R. 4 W.M.

Bearing and distance from section or subdivision corner

TL 202

(11) WATER LEVEL: Completed well.

Depth at which water was first found 97 ft.

Static level 22 ft. below land surface. Date 3/16/79

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"

Depth drilled 175 ft. Depth of completed well 175 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CLAY, BRN, BOULDERS MEDIUM, GRAVEL, Lg	0	32	
CLAY, BRN, GRAVEL, Lg	32	84	
TOMBSTONE GRANITE BEDROCK, BROWN, FRACTURED	84	165	22'
TOMBSTONE GRANITE BLACK & WHITE, VERY HARD	165	175	
Aquifer	97	145	30 g/m

Work started 3/15 19 79 Completed 3/16 19 79

Date well drilling machine moved off of well 3/16 19 79

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] D. L. Orent (Drilling Machine Operator) Date 3/16, 19 79

Drilling Machine Operator's License No. 810

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name PAQUIN WELL DRILLING INC. (Person, firm or corporation) (Type or print)

Address 1840 WILLOW LANE GRANTS PASS, ORE

[Signed] R. J. Paquin (Water Well Contractor)

Contractor's License No. 775 Date 3-19, 19 79

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119