

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

17887

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON

State Well No. 38/4W-32 ad

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

(Please type or print)

State Permit No. (128)

(1) OWNER:

Name Mr. Walbert H. Miller
Address 201 Buffalo, Applegate, Ore

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal []
Irrigation [] Test Well [] Other []

CASING INSTALLED:

6" Diam. from 0 ft. to 36 ft. Gage 250
Threaded [] Welded [X]

PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 45 gal./min. with 190 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number
SE 1/4 NE 1/4 Section 32 T. 38 S. R. 4 W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 56 (10:49 PM)
Static level 18 ft. below land surface. Date 8/26/70
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 146 ft. Depth of completed well 146 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Brown Clay (0-12), Fractured Brown Sandstone (12-40), Sandstone (40-120), Basalt (120-146).

Work started 8-25 1970 Completed 8/26 1970
Date well drilling machine moved off of well 8/26 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Steve Von Gordon Date 8/27, 1970
(Drilling Machine Operator)
Drilling Machine Operator's License No. 644

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ho. McClellan Well Drilling
(Person, firm or corporation) (Type or print)
Address 230 N.E. Elida Dr. Trout Pass
[Signed] George McClellan
(Water Well Contractor)
Contractor's License No. 432 Date 8/27, 1970