NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR - 2 1970 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
Do not write above this line

RECEIVED APR - 7 1970 STATE ENGINEER SALEM, OREGON

Jack 17888

State Well No. 38/4W-32a (28)

State Land No. G5657

(1) OWNER:
Name D. H. Miller
Address RD 1 Box 406, Applegate, Ore

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 53 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☑ Yes ☐ No.
Type of perforator used Cutting torch
Size of perforations 1/4 in. by 8 in.
42 perforations from 42 ft. to 52 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 9 ft. below land surface Date 3/31/70
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 106 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Cement & Clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 1 3/4 M.
Gravel placed from 50 ft. to 52 ft.

(11) LOCATION OF WELL:
County Jackson Driller's well number
SW ¼ NE ¼ Section 32 T. 38S R. 4W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 53 ft. Depth of completed well 106 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Fractured Sandstone	53	86	
Blue Diorite	86	106	
An existing hole 14" cased which I put 6" inside & drilled from 53 ft to 106 ft.			

Work started 3-30 1970 Completed 3-31 1970
Date well drilling machine moved off of well 3-31 1970

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Steve Van Horn (Drilling Machine Operator) Date 3-31, 1970
Drilling Machine Operator's License No. 691

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Geo. McClanahan Well Drilling (Person, firm or corporation) (Type or print)
Address 730 N.E. Ellis Dr. Grants Pass
[Signed] George McClanahan (Water Well Contractor)
Contractor's License No. 422 Date 3-31, 1970

(USE ADDITIONAL SHEETS IF NECESSARY)