RECEIVED
JAN 29 1985
WATER RESOURCES DEPT
SALEM, OREGON

JACK 18239

39S/2W-32aC

STATE OF OREGON
WATER WELL REPORT
(as required by ORS 537.765)

PLEASE TYPE or PRINT IN INK

(for official use only)

(1) OWNER:
Name LEE SMITH
Address 324 YALE CREEK RD
City JACKSONVILLE State OR

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☑ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Thermal: Withdrawal ☐ Reinjection ☐
Other: Piezometric ☐ Grounding ☐ Test ☐

(5) CASING INSTALLED:
Steel Threaded ☑ Plastic Welded ☑
6" Diam. from +1 ft. to 19 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
Steel Threaded ☐ Plastic Welded ☑
4" Diam. from 0 ft. to 100 ft. Gauge .160

(6) PERFORATIONS:
Perforated? ☑ Yes ☐ No
Size of perforations 1/8 in. by 12 in.
80 perforations from 20 ft. to 100 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test 8 gal./min. with drill stem at 100 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: Yes ☐ No ☑
Well seal—Material used CEMENT
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Amount of sealing material 6 sacks ☑ pounds ☐
How was cement grout placed? PUMPED DOWN ANNULAR SPACE
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL by legal description:
County JACKSON SW¼ NE¼ of Section 32 of
Township 39S (Township is North or South), Range 2W (Range is East or West), WM.
Tax Lot Lot Block Subdivision
MAILING ADDRESS OF WELL (or nearest address)
324 YALE CR
JACKSONVILLE OR

(11) WATER LEVEL of COMPLETED WELL:
Depth at which water was first found 50 ft.
Static level 22 ft. below land surface. Date 10-23
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CLAY	0	10	
GRANITE	10	100	

Date work started 10-23 /completed 10-23
Date well drilling machine moved off of well 10-23 1984

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Art Carter Date 11-16, 1984

(bonded) Water Well Constructor Certification:
Bond 800528 (number) Issued by: CONT. BONDING INS. CO. (Surety Company Name)
On behalf of ART CARTER (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
(Signed) Art Carter (Water Well Constructor)
(Dated) 11-16-84

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*46866-690