

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
APR 21 1970
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

(Type or print)

(Do not write above this line)

State Well No. 39/3W-15

State Permit No. _____

(1) OWNER:

Name Frank Tobey
Address Rt 2 Box 308 Jacksonville Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

6" Diam. from 2 ft. to 20 1/2 ft. Gage 350
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations	in. by	in.
_____ perforations from _____ ft. to _____ ft.		
_____ perforations from _____ ft. to _____ ft.		
_____ perforations from _____ ft. to _____ ft.		
_____ perforations from _____ ft. to _____ ft.		
_____ perforations from _____ ft. to _____ ft.		

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____

Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 10 1/2 ft. below land surface Date 4-2-70

Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Bailer test 24 gal./min. with 1/2 ft. drawdown after 1 hr.

Artesian flow _____ g.p.m. Date _____

Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 20 1/2 ft.

Diameter of well bore to bottom of seal 6 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth _____

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Jackson Driller's well number 42
Between Section 10-15 T. 39 S. R. 3 N.W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 29 ft. Depth of completed well 29 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Soil & Boulders Black	0	8	
Clay Sand & Gravel DK Green	8	16	
Clay Sand & Gravel Tan	16	19	
Clay Sand & Gravel DK Green	19	21 1/2	
Basalt LT Blue Grey Hd	21 1/2	29	
Sand - LT Green	29		
Water Bearing			

First water at 25 1/2 gal/Minute

Work started March 25 19 70 Completed April 3 19 70

Date well drilling machine moved off of well April 4, 19 70

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Clay Shultz Date 4-20, 19 70
(Drilling Machine Operator)

Drilling Machine Operator's License No. 462

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Clay Shultz
(Person, firm or corporation) (Type or print)
Address 517 Park Place NE Medford Oregon
[Signed] Clay Shultz
(Water Well Contractor)

Contractor's License No. 458 Date 4-20, 19 70