NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)



State Well No. 40s/3w-Fcd

State Permit No.

(1) OWNER: Don Fossen	(10) LOCATION OF WELL: County Jackson Driller's well number 697
Name DOIT FOSSEIT Address 11771 Upper Applegate	
1441-050	Se 48M 4 Section 8 T. 40 R. 3 W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
	Tex Lot 1700
New Well K Deepening Reconditioning Abandon I Abandon I If abandonment, describe material and procedure in Item 12.	286-19W
	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 38 ft.
Rotary XII Driven Domestic Industrial Municipal	Static level 17 ft. below land surface. Date 6/8/79
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded Ex. Signature of the control o	(12) WELL LOG: Diameter of well below casing
Type of perforator used knife	MATERIAL From To SWL
Size of perforations 2 in. by 4 in.	Clay, Brown, impervious 0 30
82 perforations from 90 ft. to 100 ft.	Clay, brown and Boulders 30 38
perforations from ft. to ft.	Rock, grey, fractured,
perforations from ft. to ft.	<u>water bearing</u> 38 100 17
(7) SCREENS: Well screen installed? Yes XX No Manufacturer's Name	
Type Model No	
Diam Slot size Set from ft. to ft.	TO PAGE
Diam Slot size Set from ft. to ft.	ACCEPTED TO
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	JUN 1 1979
Was a pump test made? ☐ Yesyty No If yes, by whom?	The property of the property o
ld: gal./min. with ft. drawdown after hrs.	GRIEM CORRES
, n , n , n , n , n , n , n , n , n , n	- Carlo Ma
## ## ## ## ## ## ## ## ## ## ## ## ##	
Haller test $5\frac{1}{2}$ gal./min. with 78 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water 52 Depth artesian flow encountered ft.	Work started 6/7/ 19 79 Completed 6/8 1979
(9) CONSTRUCTION:	Date well drilling machine moved off of well 19 ¹⁹
Well seal—Material used Cement Grout	Drilling Machine Operator's Certification:
Well sealed from land surface to ft.	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed]
Number of sacks of cement used in well seal sacks	(Driving Machine Operator)
How was cement grout placed?	Drilling Machine Operator's License No.
GIOUT Pamp and GIOP Pipo	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? 収效es 🗌 No Plugs Size: location ft.	true to the best of my knowledge and belief. Name McClanahan Well Drilling
Did any strata contain unusable water? Yes XXNo	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 141 N.E. Beacon, Grants Pass, OR
Method of sealing strata off	1 1/2 MAP 1 - V
	[Signed] (Water Well Contractor)
	Contractor's License No. 727 Date 6/13 , 19.79
Gravel placed from ft. to ft.	Outractor & Litetise 110 Date