

RECEIVED

APR 6 1966

Jack 18570

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

State Well No. 40/3w-8

STATE ENGINEER, SALEM, OREGON 97310

STATE ENGINEER STATE OF OREGON SALEM, OREGON (Please type or print)

State Permit No.

(1) OWNER:

Name DON E. FOSSEN Address E. PALMER C RD JACKSONVILLE

(2) LOCATION OF WELL:

County JACKSON Driller's well number SE 1/4 1/4 Section 8 T. 40 S R. 3 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

5" Diam. from 0 ft. to 62 ft. Gage 7

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used FLAME CUT Size of perforations in. by in. 2 1/2 x 3 perforations from 40 ft. to 60 ft.

(8) SCREENS:

Well screen installed? Yes No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal 6" WELL FORMERLY SEALED Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 8-8-66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 8 gal./min. with 160 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date 8-8-66 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 5" Depth drilled 200 ft. Depth of completed well 200 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries: hard blue grey granites 67 140, hard with an occasional joint or seam and thin lenses of white quartz - water 140 200

Work started 8-25 1966 Completed 8-8 1966 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME B. A. Studabaker (Person, firm or corporation) (Type or print) Address Rt. 2, Box 1-C Jacksonville Drilling Machine Operator's License No. 357 [Signed] B. A. Studabaker (Water Well Contractor) Contractor's License No. 356 Date 4-1 1966