NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 1 1980 WATER RESOURCES DEPT. SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

JACK 18695

State Well No. 30S/3E-34

State Permit No.

(1) OWNER:
Name U.S. FOREST SERVICE
Address P.O. Box 3623
PORTLAND, OR

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
[illegible] ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from +2 ft. to 104 ft. Gage 250
[illegible]" Diam. from ft. to ft. Gage
[illegible]" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
[illegible] a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
[illegible]er test 8 gal./min. with 193 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 18 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 6 sacks
How was cement grout placed? PRESSURE GROUTED
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County JACKSON Driller's well number 23-80
¼ ¼ Section 34 T. 30 R. 3E W.M.
Bearing and distance from section or subdivision corner
UNION CREEK COMPOUND

(11) WATER LEVEL: Completed well.
Depth at which water was first found 292 ft.
Static level 292 ft. below land surface. Date 6-14-80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 620 ft. Depth of completed well 620 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL-BROWN	0	4	
PUMICE-BROWN	4	8	
LAVA-GREY	8	26	
LAVA-GREY & BROKEN	26	68	
LAVA-GREY	68	121	
LAVA-GREY BROKEN W/CAVERNS	121	292	
LAVA-GREY W/GRAVEL	292	298	292
LAVA-GREY W/RED CINDERS	298	459	
LAVA-GREY W/BROWN CLAY	459	485	292
LAVA-GREY W/BROWN PUMICE + RED CINDERS	485	620	

Work started 6-2-1980 Completed 6-14-1980
Date well drilling machine moved off of well 6-14-1980

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [illegible] (Drilling Machine Operator) Date 6-14-1980
Drilling Machine Operator's License No. 785

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CRATER WELL DRILLING INC (Person, firm or corporation) (Type or print)
Address 2870 CRATER LAKE HWY
[Signed] [illegible] (Water Well Contractor)
Contractor's License No. 687 Date 6-14-1980

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119