

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

**RECEIVED**

**WATER WELL REPORT**

**RECEIVED**

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion

MAR 25 1978

STATE OF OREGON  
(Please type or print)

State Well No. 335/2E-30a

State Permit No. G-8000

WATER RESOURCES DEPT  
SALEM, OREGON

MAR 20 1978

**(1) OWNER:**

Name U.S. Army Escip EOR  
Address Portland, OR

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**CASING INSTALLED:**

Threaded  Welded   
12" Diam. from 0 ft. to 35 ft. Gage 3.78  
8" Diam. from 0 ft. to 60 ft. Gage 3.22

**PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Type \_\_\_\_\_ Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level.  
Was a pump test made?  Yes  No If yes, by whom? McCoy  
Yield: 150 gal./min. with 72 ft. drawdown after 5 hrs.  
50 " " 57 " " 2 "  
" 100 " " 65 " " 2 "  
Bailer test 100 gal./min. with 0 ft. drawdown after 6 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used CEMENT  
Well sealed from land surface to 60 ft.  
Diameter of well bore to bottom of seal 12 in.  
Diameter of well bore below seal 8 in.  
Number of sacks of cement used in well seal 90 sacks  
How was cement grout placed? DRRESSURE

Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County JACKSON Driller's well number I  
1/4 NE 1/4 Section 30 33 R. 2 E W.M.  
Bearing and distance from section or subdivision corner  
#1

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 60 ft.  
Static level 26 ft. below land surface. Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 8  
Depth drilled 200 ft. Depth of completed well 200 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
RED CLAY WITH BASALT BOLD	0	10	
BROWN CLAY	10	50	
LADPILLI TUFF	50	60	
LADPILLI TUFF WITH FRACTURES	60	200	

Work started 9/6/77 19 Completed 9/13/77 19  
Date well drilling machine moved off of well 9/14/77 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] R.M. Hagen Date 9/14/77, 19\_\_\_\_  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 487

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name McCoy & Son Well Drilling Co  
(Person, firm or corporation) (Type or print)  
Address 67360 Fryman Rd. Bead  
[Signed] Sol McCoy  
(Water Well Contractor)  
Contractor's License No. 594 Date 9-15, 19\_\_\_\_