

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT **RECEIVED**
STATE OF OREGON
(Please type or print) FEB 11 1975
(Do not write above this line) STATE ENGINEER

State Well No. 38S/E-30aa
State Permit No. _____

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

*Jack
19957
6-6-869*

(1) OWNER:

Name Phillip W. Curtis
Address Valley View Rd.,
Ashland, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 24 1/2 ft. Gage 12.50
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used None
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" none " " " "
" " " " " "
Bailer test 50 gal./min. with 110 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. _____
Temperature of water 58 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Concrete
Well sealed from land surface to 23 1/2 ft.
Diameter of well bore to bottom of seal 10 1/2 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 tot mix sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? good depth of strata 67-249
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number _____
N.E. 1/4 N.E. 1/4 Section S.30 T.38s R.1 E. W.M. _____
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 67 ft.
Static level 10 ft. below land surface. Date 1-24-75.
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 268 ft. Depth of completed well 268 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	3	-
Clay & Boulders	3	8	-
Conglomerate (very hard)	8	42	-
Sandstone	42	47	-
Conglomerate (very hard)	47	67	-
Broken rock	67	70	14
Conglomerate (medium)	70	75	14
Shale rock (hard)	75	93	14
Conglomerate (hard)	93	162	14
Sandstone	162	166	10
Conglomerate	166	187	10
Shale (blue, mt sticky)	187	198	10
Conglomerate	198	205	10
Sandstone	205	207	10
Conglomerate (hard)	207	245	10
Sandstone	245	249	10
Shale (blue, sticky)	249	268	10

Work started 12-19 1974 Completed 1-24 1975
Date well drilling machine moved off of well 1-24 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] E. J. Studelahn Date 1-24, 1975.
(Drilling Machine Operator)

Drilling Machine Operator's License No. 261

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name E. J. Studelahn
(Person, firm or corporation) (Type or print)

Address 55 W. Nevada St. - Ashland

[Signed] E. J. Studelahn
(Water Well Contractor)

Contractor's License No. 40 Date 1-24, 1975.