

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy  
 of this report are to be  
 filed with the  
 STATE ENGINEER, SALEM 10, OREGON  
 within 30 days from the date  
 of well completion.

RECEIVED  
 JAN 8 1964  
 STATE ENGINEER  
 SALEM, OREGON

WATER WELL REPORT  
 STATE OF OREGON  
 (Please type or print)

Jack  
 20/38

State Well No. 38/3-14  
 State Permit No.

(1) OWNER:

Name Jackson County  
 Address County Court House  
 Medford, Oregon

(2) LOCATION OF WELL:

County Jackson Driller's well number 89  
 1/4 Section 14 T. 38S R. 3E W.M.  
 Bearing and distance from section or subdivision corner 150'  
 South of North line - 800'  
 West of East line -

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

Threaded  Welded   
 \* 6" Diam. from 0 ft. to 20 ft. Gage 250  
 \* 5" Diam. from 0 ft. to 160 ft. Gage 12

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used Torch  
 Size of perforations 1/4 in. by 12 in.  
 60 perforations from 100 ft. to 160 ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name  
 Type Model No.  
 diam. Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement  
 Depth of seal 18 ft. Was a packer used? NO  
 Diameter of well bore to bottom of seal 9 in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: 1/2  
 Gravel placed from 0 ft. to 160 ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? Depth of strata  
 Method of sealing strata off

(10) WATER LEVELS:

Static level 60 ft. below land surface Date 12-9-63  
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom?  
 Yield: gal./min. with ft. drawdown after hrs.  
 " " " " "  
 " " " " "  
 Bailer test 3 gal./min. with AIR ft. drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 53 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6  
 Depth drilled 160 ft. Depth of completed well 160 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown clay	0	10
Brown claystone	10	120
Blue Claystone	120	125
Brown claystone	125	160
Water Bearing	62	63
Water Bearing	120	121

Work started 12-8 1963 Completed 12-9 1963  
 Date well drilling machine moved off of well 12-9 1963

(13) PUMP:

Manufacturer's Name  
 Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Majors Drilling Co.  
 Address 11516 Dennis Rd C.P.  
 Drilling Machine Operator's License No. 89  
 [Signed] F. Quirk  
 Contractor's License No. 384 Date 12-9-63