

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

STATE ENGINEER
SALEM OREGON

State Well No.

39/1-12

State Permit No.

(1) OWNER:

Name William D. Saunders
Address 100 Emigrant Rd. Ashland Ore

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 15 ft. below land surface Date 12-30-67
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"

Bailer test 2 1/2 gal./min. with 287 ft. drawdown after 1 1/2 hrs.
Artesian flow g.p.m. Date

Temperature of water 57 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used cement
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Jackson Driller's well number 279
1/4 1/4 Section 12 T. 39S R. 1E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 0 ft. Depth of completed well 322 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Pulled old casing at 9'			
Reamed Hole to 10' & installed 20' casing			
Soil Blackdobe	0	3	
Claystone Tan	3	7	
Sandstone Brown	7	22	
Claystone Grey water	22	15	
at 22'			
AS far as could tell this water at 22' was all that was coming in to this well. Old casing was not sealed in & well was contaminated. don't know if this will clean up the trouble but couldn't case out the 22' water & keep any water in the well capped 12-30-67			

Work started 12-27 1967 Completed 12-30 1967
Date well drilling machine moved off of well 12-30 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dallas S. Delap Date 12-30, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 62

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Dallas S. Delap well drilling
(Person, firm or corporation) (Type or print)

Address 749 Eagle Mill Rd. Ashland Ore

[Signed] Dallas S. Delap
(Water Well Contractor)

Contractor's License No. 36 Date 12-30, 1967