

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED OCT - 1 1971 STATE ENGINEER SALEM OREGON

WATER WELL REPORT STATE OF OREGON

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

Please type or print (Do not write above this line)

Jack 20566

State Well No. 39/1-24a

State Permit No. well #3

G5706

(1) OWNER:

Name: SHARLANDS INVESTMENTS INC Address: 92 BUSH ASHLAND, OREGON

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

(3) TYPE OF WELL:

Rotary [x] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [x] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

6" Diam. from 1 ft. to 24 ft. Gage 250

(5) PERFORATIONS:

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE Well sealed from land surface to 24 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal sacks Number of sacks of bentonite used in well seal 3 1/2 sacks Brand name of bentonite WYP-GEL Number of pounds of bentonite per 100 gallons of water 700 lbs./100 gals. Was a drive shoe used? [ ] Yes [x] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number 1/4 1/4 Section 24 T. 39 R. 1E W.M.

Bearing and distance from section or subdivision corner 95' SOUTH 460' WEST OF NORTHEAST PROPERTY CORNER AT WATER SYSTEM SITE

(11) WATER LEVEL: Completed well.

Depth at which water was first found 142 ft. Static level 38 ft. below land surface. Date 9-29-71 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 435 ft. Depth of completed well 435 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include SOIL, CLAY BROWN, CLAYSTONE BROWN, SANDSTONE, CLAYSTONE BLUE, SANDSTONE GRAY H., BASALT GRAY WITH QUARTZ SANDS.

Work started 9-27 1971 Completed 9-29 1971 Date well drilling machine moved off of well 9-29 1971

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Charles D. Chittwood Date 9-29, 1971 (Drilling Machine Operator) Drilling Machine Operator's License No. 71

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name CEATER WELL DRILLING INC (Person, firm or corporation) (Type or print) Address 1923 DELTA WATERS RD [Signed] Charles D. Chittwood (Water Well Contractor) Contractor's License No. 545 Date 9-29, 1971