

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
OCT 5 1967

WATER WELL REPORT

Jack
20632

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
STATE ENGINEER (Please type or print)
(Do not write above this line)
SALEM, OREGON

State Well No. 39/1-25

State Permit No. _____

(1) OWNER:

Name John Schulte
Address 467 Scenic Dr. Asklund, Ore

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 21 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 60 ft. below land surface Date 7-11-67
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baller test 75 gal./min. with air drawdown after hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 60 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement Grout
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County JACKSON Driller's well number 31
1/4 Section 25 T. 39 R. 1E W.M.
Bearing and distance from section or subdivision corner 400'
EAST - 150' NORTH of SW
SUBCORNER -

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 220 ft. Depth of completed well 220 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown sandstone	0	6	
Blue sandstone	6	220	
Water Bearing	100'	102'	60

Work started 9-9 1967 Completed 9-11 1967
Date well drilling machine moved off of well 9-11 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Fred Kabanow Date 9-11, 1967
(Drilling Machine Operator)
Drilling Machine Operator's License No. 89

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Fred Kabanow Drilling
(Person, firm or corporation) (Type or print)
Address 11516 DENNIS RD C.P.
[Signed] Fred Kabanow
(Water Well Contractor)
Contractor's License No. 384 Date 9-11, 1967