

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
WATER WELL REPORT

STATE OF OREGON
(Please type or print)

JUN - 8 1977

State Well No. 395/2E-32dc

WATER RESOURCES DEPT
SALEM, OREGON
State Permit No.

(1) OWNER:

Name Tom Kennedy
Address Ashtland Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

6" Diam. from 0 ft. to 36 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name none
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 55+ gal./min. with 22 ft. drawdown after 1 hrs.
Artesian flow g.p.m.

Temperature of water 58 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used concrete
Well sealed from land surface to 35 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 sacks
Number of sacks of bentonite used in well seal — sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? Good depth of strata 162-171
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number
SW 1/4 SE 1/4 Section 32 T39S R. 2E, W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 94 ft.
Static level 13 ft. below land surface. Date 6-3-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 177 ft. Depth of completed well 177 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	1	—
Boulders in Sandstone	1	8	—
Boulder, Coarse, Conglomerate	8	40	—
Granite, Hi-Quartz white	40	57	—
Granite white	57	65	—
Basalt Rock, Quartz bl	65	94	13
Shale Rock, Quartz Gr	94	132	13
Basalt, Hi-Quartz bl	132	141	13
Shale Rock, Hi-Quartz Gr	141	153	13
Basalt Rock, Hi-Quartz bl	153	160	13
Shale Rock, Hi-Quartz Gr	160	169	13
Basalt Rock, Hi-Quartz bl	169	177	13

Work started 5-25 19 77 Completed 6-2 19 77
Date well drilling machine moved off of well 6-3 19 77

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John Studelahn Date 6-4, 19 77
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1008

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Earl J. Studelahn (Type or print)
(Person, firm or corporation)

Address 55 W. Nevada St. - Ashtland

[Signed] Earl J. Studelahn
(Water Well Contractor)

Contractor's License No. 40 Date 6-2, 19 77