NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

Jack 21066

State Well No. 40S/2E-16da
State Permit No.

(1) OWNER:
Name Bruce McGuire
Address 180 Beacon Hill Dr.
Ashland, Ore.

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 98 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used —
Size of perforations — in. by — in. —
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: — gal./min. with — ft. drawdown after — hrs.
" " "
" " "
Bailer test 25 gal./min. with 210 ft. drawdown after 1½ hrs.
Artesian flow — g.p.m. —
Temperature of water 56 Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
How was cement grout placed? Pressure grouted
Was a drive shoe used? ☒ Yes ☐ No Plugs — Size: location — ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? good depth of strata 135-375
Method of sealing strata off —
Was well gravel packed? ☐ Yes ☒ No Size of gravel: —
Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:
County Jackson Driller's well number
NE ¼ SE ¼ Section 16 T. 40S R. 2 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 135 ft.
Static level 15 ft. below land surface. Date 11-9-79
Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 385 ft. Depth of completed well 385 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. **Report each change in position of Static Water Level and indicate principal water-bearing strata.**

MATERIAL	From	To	SWL
Soil	0	3	—
Clay (yellow, solid)	3	35	—
Shale rock	35	60	—
" "	60	135	
Shale rock (V. hard layers)	135	250	15
" "	250	375	15
Claystone (sticky)	375	385	15

RECEIVED
DEC 3 1979
WATER RESOURCES DEPT
SALEM, OREGON

Work started 10-17 1979 Completed 11-9 1979
Date well drilling machine moved off of well 11-10 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Earl J. Studebaker (Drilling Machine Operator) Date 11-10, 1979
Drilling Machine Operator's License No. 261

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Earl J. Studebaker (Person, firm or corporation) (Type or print)
Address 55 W. Nevada St. Ashland
[Signed] Earl J. Studebaker (Water Well Contractor)
Contractor's License No. 40 Date 11-10, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119