NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

JACK 2328

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 35/1W-7
State Permit No.

(1) OWNER:
Name E.D. SHEPHERD
Address 170 LOVE AIRE AV EAGLE POINT OREGON

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 16 gal./min. with 250 drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 7 sacks
How was cement grout placed? INSURTED PIPE OUTSIDE CASING PLACED CEMENT THUR PIPE UNTILL FULL
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata 112
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County JACKSON Driller's well number
¼ ¼ Section 7 T. 35 R. 1 W W.M.
Bearing and distance from section or subdivision corner
100 FOOT NORTH 150 FE FROM SW. CORNER SEC 7

(11) WATER LEVEL: Completed well.
Depth at which water was first found 112 ft.
Static level 30 ft. below land surface. Date DEC/10/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 115 ft. Depth of completed well 115 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL BROWN CLAY	0	3	
CLAY + SHALE BLUE	3	12	
BROWN + BLUE ROCK	12	115	

RECEIVED
MAY 27 1981
WATER RESOURCES DEPT
SALEM, OREGON

Work started NOV 9 1979 Completed DEC 10 1979
Date well drilling machine moved off of well DEC 11 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] U V Howlett (Drilling Machine Operator) Date DEC 10, 1979
Drilling Machine Operator's License No. 135

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name HOWLETT WELL DRILLING (Person, firm or corporation) (Type or print)
Address 3935 GREATER LAKE HWY MED
[Signed] U.V. Howlett (Water Well Contractor)
Contractor's License No. 332 Date DEC 10, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119