NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

Jack 2820

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
JUL 9 - 1976
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No.
State Permit No. 355/IW 22

(1) OWNER:
Name Kilpatrick, Charles
Address 191 Mt. View
Eagle Pt., Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 30 ft. Gage .250
..." Diam. from ft. to ft. Gage
..." Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 40 gal./min. with 52 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County JACKSON Driller's well number
¼ ¼ Section 22 T. 35 R. 1W W.M.
Bearing and distance from section or subdivision corner 105' So. 75' E. of THE N.W. PROPERTY CORNER

(11) WATER LEVEL: Completed well.
Depth at which water was first found 92 ft.
Static level 32 ft. below land surface. Date 7-2-76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 180 ft. Depth of completed well 180 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil Brown	0	1	
Clay Gravel Brown	1	3	
Clay Brown	3	9	
Clay Gravel Brown	9	11	
Clay Brown	11	22	
Clay Gravel Brown	22	25	
Clay Brown	25	28	
Clay Stone Blue	28	92	
Sandstone Broken Blue	92	93	32
Clay Stone Blue	93	167	
Sandstone Broken Blue	167	174	32
Sandstone Blue	174	180	

Work started 7-2 1976 Completed 7-2 1976
Date well drilling machine moved off of well 7-2 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] (Drilling Machine Operator) Date 7-6, 1976
Drilling Machine Operator's License No. 819

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Crater Well Drilling Inc. (Person, firm or corporation) (Type or print)
Address 1923 Delta Waters Rd. Medford
[Signed] Charles G. Gatewood (Water Well Contractor)
Contractor's License No. 545 Date 7-6, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119