

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
AUG 4 - 1972
STATE OF OREGON
STATE ENGINEER
SALEM, ORE.

STATE ENGINEER, SALEM, OREGON 97310

(Please type or print)

within 30 days from the
of well completion.

(Do not write above this line)

State Well No.

355/2W-11c

State Permit No.

(1) OWNER:

Name ROBERT HARPER
Address 10803 TABLE ROCK ROAD
CENTRAL POINT, ORE.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 21 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

AIR Return test 75 gal./min. with 196 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 9.98 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal sacks

Number of sacks of bentonite used in well seal 1 sacks

Brand name of bentonite NATIONAL BARIED

Number of pounds of bentonite per 100 gallons of water 800 lbs./100 gals.

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number
1/4 S.W. 1/4 Section 11 T. 35 S. R. 2 W. W.M.

Bearing and distance from section or subdivision corner

APPROX. 1500' EAST AND 300' N. FROM S.W. CORNER

(11) WATER LEVEL: Completed well.

Depth at which water was first found 171 ft.

Static level 29 ft. below land surface. Date 8-1-72

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 225 ft. Depth of completed well 225 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL, BROWN	0	1	
SANDSTONE, BROWN	1	15	
SANDSTONE, BLUE	15	34	
SANDSTONE, GREY	34	48	
BASALT, BLUE HARD	48	54	
SANDSTONE, BLUE	54	73	
BASALT, BLUE HARD	73	84	
SANDSTONE, BLUE	84	120	
BASALT, BLUE HARD	120	135	
SANDSTONE, BLUE	135	152	
BASALT, BLUE HARD	152	171	
SANDSTONE, BLUE	171	176	
BASALT, BLUE HARD	176	225	29

Work started 7-31-1972 Completed 8-1-1972

Date well drilling machine moved off of well 8-1-1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ronald Martinson Date 8-1, 1972
(Drilling Machine Operator)

Drilling Machine Operator's License No. 622

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name MARTINSON WELL DRILLING
(Person, firm or corporation) (Type or print)

Address 81 BALL RD. EAGLE POINT, ORE.

[Signed] J. W. Martinson
(Water Well Contractor)

Contractor's License No. 406 Date 8-1, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-45656-119