

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON APR 25 1975
(Please type or print)

State Well No. 375/4W-35dd
State Permit No.

STATE ENGINEER
SALEM, OREGON
(Do not write above this line)

JACK
35761

(1) OWNER:

Name Dennis Sigmon
Address Medford, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
4" Diam. from 0 ft. to 51 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from none to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No.
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test, 50 ft gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Concrete
Well sealed from land surface to 350 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 to 1 mix sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plug Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? good depth of strata 64-93
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number
SE 1/4 SE 1/4 Section 3 T. 38 S R. 4 W. W.M.
Bearing and distance from section or subdivision corner
Twp Lot 11606

(11) WATER LEVEL: Completed well.

Depth at which water was first found 64 ft.
Static level 33 ft. below land surface. Date 4-18-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 94 ft. Depth of completed well 94 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level, and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	2	—
Decomposed granite	2	33	—
Granite + boulders	33	43	—
Granite	43	64	—
Granite	64	94	33

Work started 4-14 1975 Completed 4-18 1975
Date well drilling machine moved off of well 4-18 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] E. J. Studelaker Date 4-18, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 261

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name E. J. Studelaker (Type or print)
Address 55 W. Nevada St. - Ashland
[Signed] E. J. Studelaker (Water Well Contractor)
Contractor's License No. 40 Date 4-18, 1975