

RECEIVED

JUL 2 1982

WATER RESOURCES DEPT
SALEM, OREGON

JACK
35385

WATER WELL REPORT
STATE OF OREGON

State Well No. 365/4W-15cb
State Permit No.

(1) OWNER:

Name City of ROGUE RIVER
Address 133 BROADWAY
City ROGUE RIVER State OR. 97537

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal ReInjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded

8" Diam. from 0 ft. to 86 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Air test 300 + gal./min. with drill stem at 71 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used CEMENT GROUT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? GROUT PUMP

Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JACKSON Driller's well number
SE 1/4 SW 1/4 Section 15 T. 36S R. 4 W W.M.
Tax Lot # Lot Blk Subdivision

Address at well location: PINE ST. BI-CENTENNIAL PARK

(11) WATER LEVEL: Completed well.

Depth at which water was first found 40 ft.
Static level 21 ft. below land surface. Date 5/25/82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 100 ft. Depth of completed well 100 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BROWN CLAY	0	10	
BROWN CLAY, COARSE GRAVEL & BOULDERS	10	30	
GRAY CLAY, COARSE GRAVEL & BOULDERS	30	45	21
LG. COARSE GRAVEL	45	90	
FRACTURED BASALT	90	100	

Work started 5/24 1982 Completed 6/2 1982
Date well drilling machine moved off of well 6/2 1982

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles D. Peltzer Date 6/17, 1982
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1479

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name McCLANAHAN WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 141 N.E. BEACON DR. GRANTS PASS, OR. 97526
[Signed] Ke McClanahan
(Water Well Contractor)

Contractor's License No. 727 Date 6/14, 1982