NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
OCT 26 1971
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(Please type or print)

(Do not write above this line)

JACK 4079

State Well No. 35/2W-29da

State Permit No. G5655

(1) OWNER:
Name Neel, Robert D.
Address 790 Ellendale
Medford, Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☑
6" Diam. from +1 ft. to 26 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 1.35 gal./min. with 311 ft. drawdown after 1½ hrs.
Artesian flow 68 g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 26 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 8 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plug Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Jackson Driller's well number
¼ ¼ Section 29 T. 35 R. 2 W.M.
Bearing and distance from section or subdivision corner 2400'
North 35' east from the south west property corner Sams Valley

(11) WATER LEVEL: Completed well.
Depth at which water was first found 308 ft.
Static level ft. below land surface. Date
Artesian pressure 1/4 lbs. per square inch. Date 10-21-71

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 315 ft. Depth of completed well 315 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil - Sandy - Brown	0	3	
Clay - Yellow	3	7	
Claystone - Yellow	7	11	
Sandstone - Brown	11	21	
Sandstone - Blue	21	308	
Sandstone - Blue Broken	308	311	Artesian
Sandstone - Blue	311	315	

Work started 10-19 1971 Completed 10-19 1971
Date well drilling machine moved off of well 10-19 1971

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles Stinson (Drilling Machine Operator) Date 10-20, 1971
Drilling Machine Operator's License No. 344

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Crater Well Drilling Inc. (Person, firm or corporation) (Type or print)
Address 1923 Delta Waters Rd. Medford
[Signed] Charles D Stinson (Water Well Contractor)
Contractor's License No. 545 Date 10-20, 1971

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119