

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No.

JUN 1 1976

State Permit No.

WATER RESOURCES DEPT.

(1) OWNER:

Name Thomas H. Thomas
Address 3285 Albion Ave
Medford, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 7 ft. to 19 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

Bar test 10 gal./min. with 89 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 5 1/2 in.
Number of sacks of cement used in well seal 52 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Jackson Driller's well number
1/4 1/4 Section 34 T. 35 R. 2W W.M.

Bearing and distance from section or subdivision corner 225 N.
150 E. of the S.W. Property
CORNER TABLE ROCK + THRESHOLD

(11) WATER LEVEL: Completed well.

Depth at which water was first found 71 ft.

Static level 24 ft. below land surface. Date 26 May 76

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	1	
CLAY	1	9	
SANDSTONE	9	71	
SANDSTONE BROKEN	71	73	24
CLAYSTONE	73	92	
CLAYSTONE	92	97	
CLAYSTONE BROKEN	97	98	24
CLAYSTONE	98	111	
CLAYSTONE BROKEN	111	113	24
CLAYSTONE	113	120	

Work started 26 May 1976 Completed 26 May 1976

Date well drilling machine moved off of well 26 May 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Eddy Corcoran Date 26 May 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 819

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Crater Well Drilling Inc.
(Person, firm or corporation) (Type or print)

Address 1923 Delta Waters Rd Medford

[Signed] Charles J. St. Louis
(Water Well Contractor)

Contractor's License No. 545 Date 5-27, 1976