NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from date of well completion.

RECEIVED NOV 13 1968 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

JACK 4402

State Well No. 35/2w-36
State Permit No.

(1) OWNER:
Name David Martin
Address 3067 Freeland RD C.P.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 42 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 30 ft. below land surface Date 10-20-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 10 gal./min. with 91 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 58 Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Cement & sand
Depth of seal 30' ft.
Diameter of well bore to bottom of seal 9 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Jackson Driller's well number 26
¼ ¼ Section 36 T. 35S R. 2W W.M.
Bearing and distance from section or subdivision corner 60' South - 100' West of NE Sub corner -

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 42 ft. Depth of completed well 42 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Brown clay w/			
Large Boulders	0	36	
Water Bearing			
Gravel 36'-42'	36	42	

Work started 10-20 1968 Completed 10-20 1968
Date well drilling machine moved off of well 10-20 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Fred Roberson Date 10-20, 1968
(Drilling Machine Operator)
Drilling Machine Operator's License No. 89

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Fred Roberson Well Drilling
(Person, firm or corporation) (Type or print)
Address 1156 Dennis RD C.P.
[Signed] Fred Roberson
(Water Well Contractor)
Contractor's License No. 384 Date 10-20, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)