## STATE OF OREGON

## WATER WELL REPORT (as required by ORS 537.765)

WATER RESOURCES DEPT. SALEM, OREGON

Juch 04423 355/3w/5 501/6907

Gribble Well Drilling

(1) OWNER: Owner's Well Number:	(9) LOCATION OF WELL by legal description:
Address14375 E.Evans Crk. Rd.	County Jackson Latitude / "Longitude / " Township 35S Nor S, Range 3W E or W, WM. Section 110
City Rogue River State Ore. Zip97537	Section 5 14 14
(2) TYPE OF WORK:	Tax Lot 110 Lot Block Subdivision Street Address of Well (or nearest address)
New Well Deepen Recondition Abandon	Street Address of Well (or nearest address) Same
<del></del>	Discontinuos of their for incursor distribution,
(3) DRILL METHOD:  Rotary Air	(10) CTATIC WATER TEVEL.
LA Rotary Air La Rotary Mud La Cable La Other	(10) STATIC WATER LEVEL:  45 ft helow lend gurface Date 9/27/89
	The below land surface.
(A) DRODOCHD TICE	Artesian pressure lb. per square inch. Date
(4) PROPOSED USE:	(11) WELL LOG: Ground elevation
Thermal Injection Other	Material From To WB? SWL
	Soil Brown 0 8
(5) BORE HOLE CONSTRUCTION:  Depth of Completed Well 160 ft.	Clay Brown 8 15
	Claystone Brown 15 31
Special Standards date of approval  HOLE SEAL Amount	Basalt Gray 31 160 91 45
Diameter From To Material From To sacks or pounds	Buddie didy
10" 0 25 Bent 0 25 800 lbs	
6" 25 160	30 gpm 91'
	30 gpm 128'
	30 gpm 136
How was seal placed? Method	30 gpm 130 -
Ŭ Other Poured Dry	p
Backfill placed fromft, toft, Material	
Gravel placed from ft. to ft. Size of gravel	AL.
(6) CASING/LINER:	
Diameter From To Gauge Steel Plastic Welded Threaded	
Casing: 6" +1 39 250 🛛 🗆	10.075
	200 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Final location of shoe(s) 39!	
(7) PERFORATIONS/SCREENS:	
Perforations Method NA	
Screens TypeMaterial	
Slot Tele/pipe "From To size Number Diameter size Casing Liner	
From To size Number Diameter size Casing Liner	5.33
	9/27/99
	Date started 9/27/89 Completed 9/27/89
(8) WELL TESTS: Minimum testing time is 1 hour	(unbonded) Water Well Constructor Certification:
Flowing	I constructed this well in compliance with Oregon well construction
☐ Pump ☐ Bailer ☐ Air ☐ Artesian	standards. Materials used and information reported above are true to my best
Yield gal/min Pumping level Drill stem at Time 90   -760   1 1/4 hr	knowledge and belief.
90 160 1 1/4 hr	Signed Date
27	
2 <sup>1</sup>	(bonded) Water Well Constructor Certification:
	I accept responsibility for construction of this well and its compliance
Temperature of water 54 Depth Artesian Flow Found	with all Oregon water well standards. This report is true to the best of my knowledge and belief.
Was a water analysis done? Yes By whom	1. mint
Did any strata contain water not suitable for intended use?   Too little  Salty Muddy Odor Colored Other	Signed 2 2 Date 10/6/89
	Cribble Well Drillian "-
Depth of strata:	Company GIIDDIE WEIT DITTE Co. 9 ob No. #705