NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED AUG 19 1966 STATE ENGINEER SALEM, OREGON

Jack 4711

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 35/4W-3M

G-3659 State Permit No.

(1) OWNER:

Name F. J. Kellems

Address Rt-1 Box 169 K Rogue River- Oreg

(2) LOCATION OF WELL:

County Jackson Driller's well number 37

¼ ¼ Section 3 T. 35S R. 4W W.M.

Bearing and distance from section or subdivision corner 400 F North 300 ft East of Section N 3.

(3) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐

Irrigation ☑ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐

Cable ☑ Jetted ☐

Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☐

8" Diam. from 0 ft. to 90 ft. Gage .352

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☑ Yes ☐ No

Type of perforator used Mills Perforator

Size of perforations 3 in. by 7 in.

120 perforations from 30 ft. to 823 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☑ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Grout

Depth of seal 20 ft. Was a packer used? no

Diameter of well bore to bottom of seal 12 in.

Were any loose strata cemented off? ☐ Yes ☑ No Depth

Was a drive shoe used? ☑ Yes ☐ No

Was well gravel packed? ☐ Yes ☑ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusable water? ☐ Yes ☑ No

Type of water? depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 7 ft. below land surface Date 7-22-66

Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☑ Yes ☐ No If yes, by whom?

Yield: 50 gal./min. with 23 ft. drawdown after 10 hrs.

" " " "

" " " "

Bailer test 40 gal./min. with 35 ft. drawdown after 2 hrs.

Artesian flow g.p.m. Date

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled ft. Depth of completed well 110 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	1
Decomposed Granite	1	65
Hard Granit	65	110

Work started 7-17 1966 Completed 7-22 1966

Date well drilling machine moved off of well 7-26 1966

(13) PUMP:

Manufacturer's Name No pump set

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME C. H. Witcher (Person, firm or corporation) (Type or print)

Address 4280 Foothill Blvd Grants Pass

Drilling Machine Operator's License No. 460

[Signed] Claude H Witcher (Water Well Contractor)

Contractor's License No. 453 Date 8-15, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)