

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

**RECORDED**  
OCT 8 1966

WATER WELL REPORT

Jack  
6007

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

STATE OF OREGON  
(Please type or print)

G-4788

State Well No. 36/1W-20 adb  
State Permit No. \_\_\_\_\_

(1) OWNER:

Name Eagle Point School  
Address Box 174  
Eagle Point, Ore.

(2) LOCATION OF WELL:

County Jackson Driller's well number \_\_\_\_\_  
1/4 Section 20 T. 36 S R. 1 W W.M.  
Bearing and distance from section or subdivision corner  
45 FT NORTH & 260 FT  
WEST OF SOUTH WEST  
CORNER

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
6" Diam. from 1 ft. to 65 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
Depth of seal 20 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 9 1/2 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 9-27-66  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test 150 gal./min. with 60 ft. drawdown after 2 hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 160 ft. Depth of completed well 160 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SOIL & BOULDERS	0	3
CLAY WITH GRAVEL	3	9
CLAY BROWN	9	26
CLAY WITH GRAVEL GREEN	26	60
CLAYSTONE GRAY	60	68
CLAYSTONE BLUE	68	93
SANDSTONE GRAY	93	102
CLAYSTONE BROWN	102	106
CLAYSTONE BLUE	106	121
SANDSTONE GRAY	121	133
SANDSTONE WHITE	133	160
WATER	93	95
	106	108
	131	135

Work started 9-27 19 66 Completed 9-27 19 66  
Date well drilling machine moved off of well 9-27 19 66

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CRATER WELL DRILLING, INC.  
(Person, firm or corporation) (Type or print)  
Address 3061 Crater Lake Ave., Medford, Ore.

Drilling Machine Operator's License No. 344

[Signed] P. A. Critwood  
(Water Well Contractor)

Contractor's License No. 83 Date 9-27, 1966